



- SHEET NOTES**
- ① UTILITY PRIMARY VAULT. VERIFY LOCATION WITH POWER COMPANY.
  - ② UTILITY TRANSFORMER. PROVIDE PAD AND LOCATE PER FUD AND OWNER DIRECTION.
  - ③ SERVICE STAND. LOCATE PER OWNER DIRECTION. SEE DETAILS.
  - ④ MARINA SUBSTATION IN NEMA 3R ALUMINUM ENCLOSURE. SEE ONE-LINE DIAGRAM. MOUNT SUBSTATION ON PRESSURE TREATED WOOD POSTS WITH BOTTOM OF UNIT MINIMUM 12" ABOVE WHARF SURFACE.
  - ⑤ PROVIDE FLEXIBLE CONNECTION FROM JUNCTION BOX ON WHARF STRUCTURE TO JUNCTION BOX ON DOCK. SEE ONE-LINE DIAGRAM FOR CONDUCTOR SIZES. SEE GANGWAY FLEXIBLE CONNECTION, SIMILAR.
  - ⑥ CONNECT PUMPOUT CONTROL PANEL. SEE ONE-LINE DIAGRAM AND PANEL SCHEDULE.
  - ⑦ SHORE POWER PEDESTAL. MIDWEST DOCKMATE OR EQUIVALENT. SEE PEDESTAL DETAIL. INSTALL IN FLOAT PODS AT LOCATIONS DIRECTED BY OWNER.
  - ⑧ LOCATE JUNCTION BOXES IN FLOAT PODS. COORDINATE WITH FLOAT MANUFACTURER.
  - ⑨ EXISTING PEDESTALS TO BE RECONNECTED IN EXISTING LOCATION TO EXISTING SERVICE. COORDINATE WITH OWNER.
  - ⑩ EXISTING PEDESTAL TO BE REMOVED.
  - ⑪ CONNECT RELOCATED HOIST TO 480V CIRCUIT. CONVERT MOTOR CONNECTION AS NECESSARY. MOTOR IS RATED 5HP, 208-230/460V.

- LEGEND**
- ⊗ SHEET NOTE
  - ◇ CIRCUIT NUMBER. SEE SCHEDULE
  - ⊠ ELECTRICAL SERVICE PEDESTAL
  - CONDUIT
  - Ⓜ JUNCTION BOX

Siuslaw River ← Ebb  
 River mile 4.7 → Flood

**SITE PLAN - ELECTRICAL**  
 1"=30'-0"

△	DATE	REVISION	BY
△	10/08	ADDENDUM 1 REVISION	GHS
△	11/08	ADDENDUM 4 REVISIONS	GHS
△	11/4/09	As Constructed	PWM

ACCOMPANIED BY DWGS. See Sht. 1

DRAFTER: \_\_\_\_\_  
 DESIGNER: \_\_\_\_\_  
 CHECKER: \_\_\_\_\_  
 REVIEWER: \_\_\_\_\_

STRUCTURE NO.	PORT OF SIUSLAW INFRASTRUCTURE IMPROVEMENTS MAPLE ST. TRANSIENT FLOAT, SIUSLAW RIVER MILE 4.7 FLORENCE, OREGON LANE COUNTY	SHEET E-1 OF 3
DATE August 2008		DRAWING NO. 80565
CALC. BOOK		
SITE PLAN - ELECTRICAL		